

# 2024 Annual Drinking Water Quality Report

## STUCKER FORK WATER UTILITY

Public Water System ID: IN5272002

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2024. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien).

For more information regarding this report, contact:

Name: Randy Needler

Phone: 812-794-0650

We want our customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled board meetings.

In our office at 2260 US HWY. 31 on the first and third Monday of each month at 4 p.m.

### Sources of Drinking Water

STUCKER FORK WATER UTILITY is Surface water.

Our water source(s) and source water assessment information are listed below:

Source Name		Type of Water	Report Status	Location
MUSCATATUCK INTAKE	RIVER	Surface water		
WELL #1		Ground water		
WELL #2		Ground water		
WELL #3		Ground water		
WELL #4		Ground water		
WELL #5	MARBLE HILL PLANT	Ground water		

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

Stucker Fork Water performed a lead service line inventory check during the previous years. That information was then compiled and submitted to the EPA and IDEM. If a lead service line was found, the customer would be notified. Stucker Fork Water found zero lead service lines going into the water meters. The public data base can be found at <https://pws-ptd.120wateraudit.com/stuckerforkin>

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your

water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

LRAA: Locational Running Annual Average

mrem: millirems per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water

picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable.

Our water system tested a minimum of 20 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	Highest RAA	Unit	Range	MRDL	MRDLG	Typical Source
CHLORINE	2024	2	ppm	0 - 1.8	4	4	Water additive used to control microbes

**Regulated Contaminants**

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Microbiological	Result	MCL	MCLG	Typical Source
COLIFORM (TCR)	In the month of June, 1 sample(s) returned as positive	Treatment Technique Trigger	0	Naturally present in the environment

Unregulated Contaminant Monitoring Rule (UCMR)	Collection Date of HV	Highest Value (HV)	Range of Sampled Result(s)	Unit
--	-----------------------	--------------------	----------------------------	------

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2020 - 2023	0.137	0.005 - 0.931	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2020 - 2023	1.62	1.04 - 5.65	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	BOOSTER STATION #7	2023 - 2024	22	14.6 - 29.7	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	DEPUTY FIRE DEPARTMENT	2023 - 2024	22	15 - 31.3	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	MARION TWP COMMUNITY CENTER	2023 - 2024	32	23.7 - 39.2	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	RURAL MEMBERSHIP	2023 - 2024	15	9.91 - 18	ppb	60	0	By-product of drinking water disinfection
TTHM	BOOSTER STATION #7	2023 - 2024	42	35.3 - 53.8	ppb	80	0	By-product of drinking water chlorination
TTHM	DEPUTY FIRE DEPARTMENT	2023 - 2024	41	33.7 - 51.1	ppb	80	0	By-product of drinking water chlorination
TTHM	MARION TWP COMMUNITY CENTER	2023 - 2024	52	38.4 - 66.5	ppb	80	0	By-product of drinking water chlorination
TTHM	RURAL MEMBERSHIP	2023 - 2024	28	21.1 - 33.6	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARIUM	5/16/2024	0.046	0.046	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

FLUORIDE	5/16/2024	0.616	0.616	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	5/16/2024	1.06	0 - 1.06	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
GROSS ALPHA, EXCL. RADON & U	6/20/2022	0.358	0.046 - 0.358	pCi/L	15	0	Erosion of natural deposits
RADIUM-228	6/20/2022	0.258	0.258	PCI/L	5	0	

### **Turbidity**

Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration.

Percentage of samples in compliance with Std	Months Occurred	Violation	Highest Single Measurement	Month Occurred	Sources	Level Indicator
100.00	12	NO	0.39	March	TREATMENT PLANT #2 - AUSTIN (SW)	Yes

### **Total Organic Carbon**

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

TOC	Collection Date	Highest Value	Range	Unit	TT	Typical Source
CARBON, TOTAL	12/18/2024	8.82	0 - 8.82	MG/L	0	Naturally present in the environment

### **Violations**

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explanation
12/31/2020 - 1/15/2024	LEAD & COPPER RULE	LEAD CONSUMER NOTICE (LCR)	Failed to meet content, delivery, and/or reporting requirements for lead consumer notification

Additional Required Health Effects Language:

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

There are no additional required health effects violation notices.

**Deficiencies**

Unresolved significant deficiencies that were identified during a survey done on the water system are shown below.

Date Identified	Facility	Code	Activity	Due Date	Description
-----------------	----------	------	----------	----------	-------------

No deficiencies during this period.